

RFI 1) Did SAWS have any advance warning that rolling outages would knock water pumping stations offline? **No**. Did SAWS agree or consent to these facilities being blacked out or were these downed facilities accounted for in previously established emergency protocols? (What prior agreements dictate conduct between SAWS and CPSE in emergency instances like this and were these agreements executed as planned?) *SAWS and CPSE have procedures established for emergency restarts after a grid fails for some reason. This restart queue identifies for CPSE where SAWS has pumping stations and other facilities that have priority in restoring a circuit. For the February event, SAWS assisted CPSE in working to maintain water service to the maximum extent possible as CPSE was being asked to continue to shed electrical loads.*

There are no prior agreements between SAWS and CPSE for taking water pumping stations off line.